

Q&R NO. 1

2022 SEWER SYSTEM IMPROVEMENTS

**CITY OF WAVERLY
WAVERLY, TENNESSEE**

QUESTIONS & RESPONSES

1. Q: The pump spec calls for a ceramic coating at 15 mils DFT for all metal materials in contact with the pumped liquid (refer to 2.04.E). Due to the cost, ceramic coatings (Belzona or similar) are typically reserved to the impeller and volute interior. Was it your intent for the exterior of the pumps/motors to also be coated?

R: No, the intent was only the impeller and volute interior would be coated.

2. Q: The Sam.gov registration number is requested twice in the bid package. Is it a requirement for this job? Does it cost \$600 to register?

R: Yes, a SAMs registration is required for the project. There is no cost to register by using the "sam.gov" website.