

Q&R NO. 2

BUFFALO WATER TANK REPLACEMENT

**CITY OF WAVERLY
WAVERLY, TENNESSEE**

QUESTIONS & RESPONSES

1. Q: Looking at the Buffalo Tank Waterline Replacement, I am not seeing the specs for the ductile and valves. Do you have the specs on the ductile (i.e. Class 350 or Class 52) as well as the valves (American Flow approval)?

R: Pipe shall be Class 350 as indicated on Drawing G-001 Note 2 and in Spec Section 40 20 00 Part 2.2. Valves shall be as indicated on Drawing G-001 Note 10.