


TOSHA
25 MOST CITED PUBLIC SECTOR STANDARDS
 January 1, 2008–December 31, 2008



Rank	#Cited	Standard	Hazard Description
1	86	1910.1200(e)(1)	No Written Hazard Communication Program
2	73	1910.157(e)(2)	No Monthly Visual Inspection of Fire Extinguishers
3	55	1910.1200(g)(1)	No MSDS for Hazardous Chemicals
4	53	1910.215(b)(9)	Missing Tongue Guard on Grinder
5	51	1910.1200(h)(1)	Inadequate Training on Hazardous Chemicals
6	47	0800-1-9-.06(2)	No Non-containerized Chemical Warnings
7	44	1910.305(b)(1)(ii)	Unused Openings in Cabinets, Boxes, and Fittings Not Effectively Closed
8	36	1910.304(g)(5)	No Permanent or Continuous Electrical Path to Ground
9	35	1910.305(b)(2)	No Covers on Pull Boxes, Junction Boxes, and Fittings
10	35	1910.303(g)(1)(ii)	No Clear Space In Front Of Electrical Panel
11	35	1910.215(a)(4)	Missing Work Rest on Grinder
12	35	1910.157(e)(3)	No Annual Maintenance Check of Portable Fire Extinguishers
13	32	1910.303(f)(2)	Electrical Disconnecting Means Not Legibly Marked
14	30	1910.1030(c)(1)(i)	No Written Exposure Control Plan
15	28	1910.305(j)(2)(iv)	Receptacle in Wet or Damp Location Not Suitable for the Location
16	27	1910.212(b)	Machinery Not Securely Anchored
17	26	1910.157(c)(1)	Portable Fire Extinguishers Not Accessible
18	24	0800-1-9-.07(1)	No Annual Training on Hazardous Chemicals
19	23	1910.305(a)(4)(v)	Electrical Wires Within 7 Feet of Floor Not Protected
20	23	1910.22(d)(1)	No Sign Indicating Approved Load Level (Overhead Storage)
21	21	1910.303(g)(1)(i)	Workspace Maintained Less Than 30 inches in Front of Electric Equipment.
22	20	1910.303(b)(2)	Electrical Equipment Not Installed and Used in Accordance with Listing or Labeling
23	20	1910.244(a)(1)(ii)	Rated Load Not Marked on Jacks
24	20	1910.151(c)	No Emergency Eye Wash and/or Shower
25	19	305(g)(1)(iv)	Improper Use of Flexible Cords