STATE OF TENNESSEE
DEPARTMENT OF COMMERCE & INSURANCE
STATE FIRE MARSHAL'S OFFICE
500 James Robertson Pkwy.
Nashville, TN 37243 1162
Fax: (615) 253-4895

RESIDENTIAL FOOTING/SLAB INSPECTION

(A) - All Items Approved
(C) - Correction needed or work incomplete
(N/A) - Not applicable

Permit # _____ Date: _____

Street: _____

City: _____ County: _____

☐ Re-inspection

IRC	Footings	Result
403.1.4	Minimum 12" below undisturbed soil	
403.1.1	Minimum footing width required by Table 403.1 Minimum 6" thick	
403.1	Undisturbed soil or engineered fill	
403.1.3	Seismic Category D: Rebar Placement 3" min. from bottom of footing	
403.1.5	Footings are stepped where slope is 1:10 or more	

IRC	Slabs	Result
506.1	Slab minimum 3.5" thick	
506.2.1	Vegetation, top soil and foreign materials removed from site and fill	
506.2.2	Below grade slabs on 4" base of sand, gravel or crushed stone	
401.4	Fill compaction test	
506.2.3	6 mil vapor retarder with 6" laps	
506.2.4	Reinforcement supported at center or upper third (where provided)	

Code Reference	Comments, Correction Needed, Work Incomplete

☐ Passed ☐ Failed, Reinspection Required

Inspector Number: _____ Inspector's Signature _____