

REPLACEMENT OF STAMPED DATA FORM
in accordance with provisions of the *National Board Inspection Code*

Submitted to

(name of jurisdiction)

(address)

(telephone no.)

Submitted by

(name of owner.)

(address)

(telephone no.)

1. Manufactured by _____

(name and address)

2. Manufactured for _____

(name and address)

3. Location of installation _____

(address)

4. Date installed _____

5. Previously installed at _____

6. Manufacturer's Data Report attached No Yes

7. Item registered with National Board No Yes, NB Number _____

8. Item identification _____ Year built _____

Type _____ Dimensions _____

Mfg. serial no. _____ Jurisdiction no. _____

MAWP _____ psi Safety relief valve set at _____ psi

9. Complete the reverse side of this report with a true facsimile of the legible portion of the nameplate.

10. If nameplate is lost or illegible, documentation shall be attached identifying the object to the Manufacturer's Data Report referenced on this form.

11. I request authorization to replace the stamped data and/or nameplate on the above described pressure-retaining item in accordance with the rules of the *National Board Inspection Code* (NBIC).

Owner or User's name _____

Signature _____ Date _____

Title _____

12. Authorization is granted to replace the stamped data or to replace the nameplate of the above described pressure-retaining item.

Signature _____ Date _____

(chief inspector or authorized representative)

Jurisdiction _____

The following is a true facsimile of the legible portion of the item's nameplate. Please print. Where possible, also attach a rubbing of the nameplate.

I certify that to the best of my knowledge and belief, the statements in this report are correct, and that the replacement information, data, and identification numbers are correct and in accordance with provisions of the *National Board Inspection Code*. Attached is a facsimile or rubbing of the stamping or nameplate.

Name of Owner or User _____

Signature _____ Date _____
(authorized representative)

Witnessed by _____ Employer _____
(name of inspector)

Signature _____ Date _____ NB Commission _____
(inspector)

(Back)

PART 2, SECTION 5 INSPECTION — STAMPING, DOCUMENTATION, AND FORMS

5.1 SCOPE

This Section provides guidelines and requirements for stamping and documentation (Forms) for inservice inspections of PRIs. This Section also describes evaluation of inspection results and assessment methodologies.

5.2 REPLACEMENT OF STAMPING DURING INSERVICE INSPECTION

5.2.1 AUTHORIZATION

- a) When the stamping on a pressure-retaining item becomes indistinct or the nameplate is lost, illegible, or detached, but traceability to the original pressure-retaining item is still possible, the Inspector shall instruct the owner or user to have the stamped data replaced. All re-stamping shall be done in accordance with the original code of construction, except as modified herein. Requests for permission to re-stamp or replace nameplates shall be made to the Jurisdiction in which the pressure-retaining item is installed. Application must be made on the *Replacement of Stamped Data Form*, NB-136 (see NBIC Part 2, 5.3.2). Proof of the original stamping and other such data, as is available, shall be furnished with the request. Permission from the Jurisdiction is not required for the reattachment of nameplates that are partially attached. When traceability cannot be established, the Jurisdiction shall be contacted.
- b) When there is no Jurisdiction, the replacement of stamped data shall be authorized and witnessed by a National Board Commissioned Inspector and the completed Form NB-136 shall be submitted to the National Board.

5.2.2 REPLACEMENT OF STAMPED DATA

- a) The re-stamping or replacement of data shall be witnessed by a National Board Commissioned Inspector and shall be identical to the original stamping.
- b) The re-stamping or replacement of a code symbol stamp shall be performed only as permitted by the governing code of construction.
- c) Replacement nameplates shall be clearly marked “replacement.”

5.2.3 REPORTING

Form NB-136 shall be filed with the Jurisdiction (if required) or the National Board by the owner or user together with a facsimile of the stamping or nameplate, as applied, and shall also bear the signature of the National Board Commissioned Inspector who witnessed the replacement.