



STATE OF TENNESSEE
ENVIRONMENT AND COSERVATION

**INVITATION TO BID # 32701-13234
AMENDMENT # 1
FOR OLD STONE FORT STATE PARK ASPHALT
ACCESS**

DATE: 3/14/2024

ITB # 32701-13234 IS AMENDED AS FOLLOWS:

1. This ITB Schedule of Events updates and confirms scheduled ITB dates. Any event, time, or date containing revised or new text is highlighted.

Event Posted	8:00 am CT	3-4-2024
Questions and Comments Due	4:30 pm CT	3-12-2024
Bids Due	2:00 pm CT	3-25-2024

2. State responses to questions and comments in the table below amend and clarify this ITB.

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		Environmental Permitting – The State of Tennessee manages all Environmental Permitting?	No permit required.
SOW	PG 2	Erosion Control – No erosion control measures are required for the project?	None other than what is mentioned in the scope.
		Access – Contractor will have complete access to the work area and no Park Guest are allowed in the work area during construction?	Yes, as discussed with Park Manager during the Pre-Bid.
SOW	PG 3	Scope – Culvert – there are now three culverts to be installed?	No, two will remain with proper drainage.
SOW	PG 2	Scope – Demolition – The existing, 124', asphalt road does not need to be removed? Contractor can score the surface and scab on existing asphalt (with widening, per Specification).	Yes, to be scored as discussed at Pre-Bid.
SOW	PG 3	Scope – Grading – New Asphalt Road Area (376')- Basic surface grading is required? Then placement of 6" of stone, then 2"	Yes, as mentioned in the Scope of Work.

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		of base asphalt, and 1.5" of top asphalt?	

3. **ITB Amendment Effective Date.** The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.